

INSPECTION RECORD



Model No. _____
Serial No. _____
Date Installed New: _____

INSPECTION should be performed monthly, or more frequently if circumstances warrant. The extinguisher should be checked to verify that it is not damaged, that the discharge outlet is not obstructed in any manner, that the tamper seal is intact, and that the operating instructions are clearly visible and legible.

ANNUAL MAINTENANCE is a more comprehensive inspection of the extinguisher and should be done by a trained professional. It will determine the need for hydrostatic testing of the unit. Hydrostatic testing is required every five years on Wet Chemical, Water, Water Mist, and Carbon Dioxide extinguishers. Dry Chemical and Halotron extinguishers are hydrotested every twelve years. Contact your local authorities about extinguisher testing. The legs to the extinguisher as verification of this service.

SIX-YEAR MAINTENANCE SERVICE is required for extinguishers that are on the twelve-year hydrotest cycle. Every six years the extinguisher shall be emptied and undergo a thorough examination of its mechanical parts, extinguishing agent, and its means of expulsion. Note: Removal of the agent in Halotron extinguishers shall only be done with a UL approved closed recovery system. When the applicable maintenance procedures are being performed, the legs to the extinguisher, the six-year requirement will begin from that date.

RECHARGE of the extinguisher should be done by trained personnel at your local Buckeye Distributor immediately after any use. The Distributor has the extinguishing agent and the equipment necessary to perform the recharge properly. The extinguisher must be recharged with the extinguishing agent specified on the nameplate. Substitution could cause damage or injury.

CAUTION

ABC Dry Chemical extinguishers are not recommended for use in swimming pool chemical storage areas. Also, they should not be installed in kitchens where they might be used on cooking grease fires. Wet Chemical is the extinguishing agent recommended for this type of fire. USE OF DRY OR WET CHEMICAL AGENT EXTINGUISHERS ON FIRES INVOLVING DELICATE ELECTRONIC EQUIPMENT IS NOT RECOMMENDED. THEY MAY SUCCESSFULLY EXTINGUISH THE FIRE BUT WILL ALSO DAMAGE THE EQUIPMENT BEYOND REPAIR.

INSPECTION

This extinguisher should be inspected monthly for any possible damage, corrosion, leakage, or obstructions in the discharge outlet.

Check the tamper seal to be sure that it is intact. Check for any dents or damage to the extinguisher body and discharge valve assembly. Clean the extinguisher so that the instructions on the nameplate are clearly visible. Weigh the extinguisher to verify the full weight is within the tolerance indicated on the nameplate.

For extinguishers with pressure gauges, check the needle indicator. It should be in the green area and pointing straight up. NOTE: Changes in temperature may cause the indicator on the pressure gauge to vary within the Green area on stored pressure type extinguishers. The Green area is the "charged" zone. When the temperature is cold the indicator may read on the low side of the "charged" zone and if the temperature is hot it may read on the high side of the "charged" zone. The true reading of the pressure may be verified by placing the extinguisher at room temperature (70°F) for 24 hours.

If any anomalies are found during the inspection please notify your local Buckeye Distributor for a thorough inspection and resolution.

AN INSPECTION TAG IS INCORPORATED INTO THIS OWNER'S MANUAL. PLEASE DETACH IT, HANG IT ON THE EXTINGUISHER, AND RECORD YOUR MONTHLY INSPECTIONS.

CAUTION

DO NOT INCINERATE. The charged extinguisher is pressurized and may explode

KEEP EXTINGUISHER OUT OF THE REACH OF SMALL CHILDREN.



ISO 9001 REGISTERED

OWNER'S MANUAL AND WARRANTY FOR YOUR HAND PORTABLE FIRE EXTINGUISHERS

INTRODUCTION

This fire extinguisher has been manufactured by Buckeye Fire Equipment Company. It has been designed with ease of use, effective fire fighting capabilities, and long service life as the paramount standards. Dedicated quality control and modern manufacturing facilities provide you with the best fire extinguisher value in the fire protection industry. Buckeye's quality of workmanship is exhibited in its guarantee to repair or replace any extinguisher that exhibits any defect in workmanship or material during the length of the warranty period.

BUCKEYE FIRE EQUIPMENT CO.

110 KINGS ROAD
KINGS MOUNTAIN, NC
28086-0428

Phone: 704.739.7415
Fax: 704.739.7418

e-mail: bfec@buckeyef.com

OM001 11/2008