

## Architectural Series Fire Extinguisher Cabinets Submittal and Detail Sheet

PROJECT:	LOCATION:
MODEL NUMBER:	QUANTITY:
ARCHITECT:	CONTRACTOR:
DATE:	DISTRIBUTOR: Hallmann Sales

## SPECIFICATIONS:


All recessed and semi-recessed cabinets and surface-mounted steel cabinets have a heavy gauge, white baked enamel box. Surface-mounted cabinets with aluminum door and trim have a box constructed entirely of clear or color anodized aluminum. Surface-mounted cabinets with stainless steel door and trim have a box constructed entirely of 304 stainless steel with a #4 finish.


Steel and stainless steel cabinets have a full ½" thick hollow metal heavy gauge door. Trims and doors feature one piece construction with satin finish pull handle, continuous matching hinge, and self-adjusting roller catch. Baked white enamel finish is standard for steel units. Stainless steel cabinets have a #4 finish, 304 stainless steel.


Aluminum cabinet doors and trims are extruded or fabricated aluminum with clear satin anodized finish. Aluminum door is ½" thick with satin finish matching pull handle and hinge. Color anodized finishes are available as options.


STEP 1: Select cabinet model number from the dimensions on page 2 and indicate on the top of this sheet. To specify aluminum trim and door, use the prefix, "AL" before the model number. To specify stainless steel trim and door, use the prefix, "SS" before the model number. Note:

Rough opening dimensions are larger for fire-rated cabinets. Please refer to separate Fire-Rated Cabinet Submittal and Detail Sheet.









- † Trimless cabinets must be installed before the drywall because their plaster stops must be behind the drywall. Trimless cabinets are not recommended for block wall installation.
- \* See back of this sheet or attached sheet for Recessed Handle (required only for 4" return trims when ADA wall projection compliance is necessary)

LARSEN'S MANUFACTURING COMPANY - www.larsensmfg.com

7421 Commerce Lane N.E., Minneapolis, MN 55432 Phone: (763) 571-1181 FAX: (763) 571-6900


FLORIDA DIVISION: 3130 N.W. 17th Street, Ft. Lauderdale, FL 33311 Phone: (954) 486-3325 FAX: (954) 486-3352

## **CABINET DIMENSIONS - ARCHITECTURAL SERIES**

Model Number	Trim Style and Projection	Inside Box Dimensions		Outside Trim Dimensions**		Rough Opening***			Recommended Extinguisher	
		Height	Width	Depth	Height	Width	Height	Width	Depth	Capacity
2409-R1 2409-5R 2409-R3	Rec. 5/16" Semi-Rec. 1½" Semi-Rec. 2½"	24" 24" 24"	9½" 9½" 9½"	5"* 5"* 5"*	27½" 27½" 27½"	13" 13" 13"	25" 25" 25"	10½" 10½" 10½"	5½" 4" 3"	MP 2½, MP5,MP5-A, DC2½,DC5, HT2½"HT5
☐ 2409-R2 ☐ 2409-R7 ☐ 2409-6R ☐ 2409-R4 ☐ 2409-RM ☐ 2409-SM ☐ 2409-RA	Rec. 5/16" Semi-Rec. 1½" Semi-Rec. 2½" Semi-Rec. 3½" Semi-Rec. 4½" Trimless Surface Mounted Semi-Rec. 4"	24" 24" 24" 24" 24" 24" 24" 27½" 24"	9½" 9½" 9½" 9½ 9½ 9½" 13" 9½"	6" 6" 6" 6" 6"	27½" 27½" 27½" 27½" 27½" 27½" - 27½" 27½"	13" 13" 13" 13" 13" - 13" 13"	25" 25" 25" 25" 25" 1 - 25"	10½" 10½" 10½" 10½" 10½" 10½" † - 10½"	6½" 5" 4" 3" 2" 6½" - 2½"	MP 2½,MP5, MP5-A, DC2½,DC5 MP6,MP10 DC6,DC10,CD5 HT2½", HT5
Deput is 4/4 when supplied with administration door and till. The AL2409-01 has a 1/4 square till.										
☐ 2712-R ☐ 2712-RK ☐ 2712-RL ☐ 2712-RM ☐ 2712-RT ☐ 2712-SM ☐ 2712-RA	Rec. 5/16" Semi-Rec. 11/4" Semi-Rec. 21/2" Semi-Rec. 41/2" Trimless Surface Mounted Semi-Rec. 4"	27" 27" 27" 27" 27" 27" 30½" 27"	12" 12" 12" 12" 12" 15½" 15½"	8" 8" 8" 8" 81/2" 8"	30½" 30½" 30½" 30½" - 30½" 30½"	15½" 15½" 15½" 15½" 15½" † 15½" 15½"	28" 28" 28" 28" † - 28"	13" 13" 13" 13" † - 13"	8½" 7½" 6" 4" 8½" - 4½"	All of Above, PW 2½",MP20, DC20,CD10 WC-6L HT11, HT15½"
☐ 2720-R ☐ 2720-RK ☐ 2720-RL ☐ 2720-RM ☐ 2720-RT ☐ 2720-SM ☐ 2720-RA	Rec. 5/16" Semi-Rec. 1½" Semi-Rec. 2½" Semi-Rec. 4½" Trimless Surface Mounted Semi-Rec. 4"	27" 27" 27" 27" 27" 27" 30½" 27"	20" 20" 20" 20" 20" 23½" 20"	8" 8" 8" 8" 8" 8½" 8"	30½" 30½" 30½" 30½" - 30½" - 30½"	23½" 23½" 23½" 23½" - 23½" - 23½"	28" 28" 28" 28" † - 28"	21" 21" 21" 21" † - 21"	8½" 7½" 6" 4" 8½" - 4½"	Two Each of The listed: PW2½",MP10, DC10,MP20, DC20,CD5, D10 WC-6L,HT11, HT15½"
☐ 3012-R ☐ 3012-RK ☐ 3012-RL ☐ 3012-RM ☐ 3012-RT ☐ 3012-SM ☐ 3012-RA	Rec. 5/16" Semi-Rec. 11/4" Semi-Rec. 21/2" Semi-Rec. 41/2" Trimless Surface Mounted Semi-Rec. 4"	30" 30" 30" 30" 30" 31½" 30"	12" 12" 12" 12" 12" 15½" 15½"	8" 8" 8" 8" 8" 8½" 8"	33½" 33½" 33½" 33½" - 33½" 33½"	15½" 15½" 15½" 15½" - 15½" 15½"	31" 31" 31" 31" † - 31"	13" 13" 13" 13" † - 13"	8½" 7½" 6" 4" 8½" - 4½"	Same as 2712
☐ 3612-R ☐ 3612-RK	Rec. 5/16" Semi-Rec. 11/4"	36" 36"	12" 12"	8" 8"	39½" 39½"	15½" 15½"	37" 37"	13" 13"	81/4" 71/4"	Same as 2712
3612-RL 3612-RM 3612-RT 3612-RT 3612-SM 3612-RA	Semi-Rec. 1/4 Semi-Rec. 2½" Semi-Rec. 4½" Trimless Surface Mounted Semi-Rec. 4"	36" 36" 36" 36" 39½" 36"	12" 12" 12" 12" 15½" 15½"	8" 8" 8" 8½" 8"	39½" 39½" 39½" - 39½" 39½"	15½" 15½" 15½" - 15½" 15½"	37" 37" † - 37"	13" 13" 13" † - 13"	6" 4" 8½" - 4½"	FB 3612 OPTION:  W/Shelf & Fire Blanket
☐M3216-R ☐M3216-RK ☐M3216-RL ☐M3216-RM ☐M3216-RT ☐M3216-SM ☐M3216-RA	Rec. 5/16" Semi-Rec. 11/4" Semi-Rec. 21/2" Semi-Rec. 41/2" Trimless Surface Mounted Semi-Rec. 4"	32" 32" 32" 32" 32" 35½" 35½"	16" 16" 16" 16" 16" 19½"	8" 8" 8" 8" 8" 8½" 8"	35½" 35½" 35½" 35½" - 35½" 35½"	19½" 19½" 19½" 19½" - 19½" 19½"	33" 33" 33" † - 33"	17" 17" 17" 17" † -	8½" 7½" 6" 4" 8½" - 4½"	PW2½",MP20, DC20,CD10, CD15, WM2½"

<sup>†</sup> Trimless cabinets must be installed before the drywall because their plaster stops must be behind the drywall. Trimless cabinets are not recommended for block wall installation

NOTE: Semi-recessed and surface-mounted cabinet compliance with ADA wall projection guidelines depends on several location and installation issues.



LARSEN'S MANUFACTURING COMPANY - www.larsensmfg.com

7421 Commerce Lane N.E., Mpls, MN 55432 Phone: (763) 571-1181 FAX: (763) 571-6900

FLORIDA DIVISION: 3130 N.W. 17th Street, Ft. Lauderdale, FL 33311 Phone: (954) 486-3325 FAX: (954) 486-3352

<sup>\*\*</sup> Deduct 3/4" from HxW dimensions for cabinets with aluminum trim.

<sup>\*\*\*</sup> Rough openings are larger for fire-rated cabinets. Please refer to Fire-rated Extinguisher Cabinet Submittal and Detail Sheet.